



产品认证证书

证书编号: CQC2010010308421737

申请人名称及地址

美尔森电气系统(浙江)有限公司
浙江省湖州市长兴技术开发区陈王路1228号2号厂房

制造商名称及地址

美尔森电气系统(浙江)有限公司
浙江省湖州市长兴技术开发区陈王路1228号2号厂房

生产企业名称及地址

美尔森电气系统(浙江)有限公司(V055926)
浙江省湖州市长兴技术开发区陈王路1228号2号厂房

产品名称和系列、规格、型号

低压熔断器(刀型触头熔断器)

熔断体型号:NH00;熔断体的额定电压:500V/690V;熔断体的额定电流:2A,4A,6A,8A,10A,16A,20A,25A,32A,40A,50A,63A,80A,100A,125A,160A(500V);2A,4A,6A,8A,10A,16A,20A,25A,32A,40A,50A,63A,80A,100A(690V);额定分断能力:100kA(500V),50kA(690V);分断范围和使用类别:gG;熔断体支持件型号:NH00;熔断体支持件的额定电压:690V;熔断体支持件的额定电流:160A;极数:1P;峰值耐受电流:100kA

产品标准和技术要求

GB/T 13539.2-2015

认证模式

产品型式试验+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求,特发此证。

发证日期:2020年10月31日 有效期至:2024年12月23日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书,证书首次颁发日期:2020年04月24日

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0410361



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010308421737

NAME AND ADDRESS OF THE APPLICANT

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, China.

NAME AND ADDRESS OF THE MANUFACTURER

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, China.

NAME AND ADDRESS OF THE FACTORY

MERSEN ZHEJIANG CO., LTD. (V055926)

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, China.

PRODUCT NAME, MODEL AND SPECIFICATION

Fuse with breaking capacity of all ranges

Fuse Model:NH00; Un:500V/690V;In:2A,4A,6A,8A,10A,16A,20A,25A,32A,40A, 50A,63A,80A,100A,125A,160A(500V);2A,4A,6A,8A,10A,16A,20A,25A,32A,40A, 50A,63A,80A,100A(690V);I1:100kA(500V),50kA(690V);Breaking Range and Utilization Category:gG; Fuse-holder Model:NH00; Un:690V;In:160A;Poles:1P;Peak Withstand Current:100kA

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.2-2015

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Oct.31,2020

Valid until: Dec.23,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.24,2020

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0410361