



# 产品认证证书

证书编号：CQC2019010308260507

## 申请人名称及地址

美尔森电气系统（浙江）有限公司  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

## 制造商名称及地址

美尔森电气系统（浙江）有限公司  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

## 生产企业名称及地址

美尔森电气系统（浙江）有限公司 (V055926)  
浙江省湖州市长兴技术开发区陈王路 1228 号 2 号厂房

## 产品名称和系列、规格、型号

半导体设备保护用熔断体

RGS11;Un: AC250V, DC170V;In: 6A、8A、10A、12A、16A、20A、25A、30A、32A、35A、40A、45A、50A、55A、60A、63A、70A、75A、80A、85A、90A、100A、110A、120A、125A;额定分断能力: 80kA(AC250V), 50kA(DC170V);分断范围和使用类别:aR

## 产品标准和技术要求

GB/T 13539.4-2016

## 认证模式

产品型式试验+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求，特发此证。

发证日期：2020 年 10 月 31 日 有效期至：2024 年 12 月 16 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2020 年 04 月 24 日

主任：陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0425482



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2019010308260507

## NAME AND ADDRESS OF THE APPLICANT

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

MERSEN ZHEJIANG CO., LTD.

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE FACTORY

MERSEN ZHEJIANG CO., LTD. (V055926)

Building 2#, No. 1228, Chenwang Road, Technical Development Zone, Changxing, Huzhou City, Zhejiang Province, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Fuse-links for the Protection of Semiconductor Devices

RGS11;Un: AC250V, DC170V;In: 6A、8A、10A、12A、16A、20A、25A、30A、32A、35A、40A、45A、50A、55A、60A、63A、70A、75A、80A、85A、90A、100A、110A、120A、125A;Iq: 80kA(AC250V), 50kA(DC170V);Breaking Range and Utilization Category:aR

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Oct.31,2020

Valid until: Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Apr.24,2020

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0425482